

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0694:174 Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02154-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Model 7200 fire alarm control unit. Power-limited; coded, noncoded or marchtime, local; auxiliary, remote station, central station and proprietary signaling system; waterflow, releasing device and sprinkler supervision. Refer to listee's data sheet for detailed product description and operational considerations. System components:

CAB/B, CAB/C, CAB/D, CAB/A	Cabinet
7200MP/B, 7200MP/A	Mounting Plate
PSU, SPSU	Power Supply Unit
ACU	AC Unit
XFMR	Transformer Assembly
SCU	System Control Unit
QZU	Quad Zone Unit
ALU	Analog Loop Unit
KDU	Keyboard Display Unit
EZU	Eight Zone Unit
FACT	Digital Alarm Comm Transmitter
ATTE-B	Elec. Actuated Alarm Transmitter
DSU	Dual Signal Unit
ZCU	Zone Coder Unit
EZD	Eight Zone Daughterboard
HRU	High Current Relay Unit
QRU	Quad Relay Unit
PBA	Panel Bus Adapter
EZA	8-Zone Annunciator Board
KDU-L	Keyboard Display Unit
DIU	Distributed Intelligent Unit
FV-7200 ME, FV-7200 SD	Enclosure
SPSU-V	Switching Power Supply
ATU	Abort timer Unit
RDU	Releasing Device Unit
ADC	Audio Driver Card
BAU	Bulk Amplification Unit
PA-120, -250	Amplifiers
FCI-AAM-25	Audio Amplifier Module
IDU	Addressable Interface

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to listee's Installation Manual for details.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager